

LEVEL 1 - User	A ON/OFF Reg. 25°C 65%	B Temp. reg. 25°C 65%	C Humidity reg. 25°C 65%	D Timer	X Service
	A01 ON Time 10 sec	B01 Min. temp. 20°C	C01 Min. Humidity 60%	D01 Timer 1 ON/OFF OFF, ON	X01 Level select 1 2, 3
	A02 OFF Time 10 sec	B02 Max. Temp. 30 °C	C02 Max. Humidity 75%	D02 Timer 1 ON Time 08.00	X02 Show Date/Time Date Time
	A03 Wetting OFF, ON	B03 Fixed On Time 10 sec	C03 Fixed On Time 10 sec	D03 Timer 1 OFF Time 20.00	X03 SW version Just info
LEVEL 2	A11 Dust - manuel 60 sec	B11 OFF various 120 sec max	C11 OFF various 120 sec max	D11 Timer 2 ON/OFF OFF, ON	X11 ON Time
	A12 Disinfection OFF, ON	B12 Off Time Min 0	C12 Off Time Min 0	D12 Timer 2 ON Time 08.00	X12 Reset To Default No Yes
LEVEL 3	A21 Dust - Auto OFF, ON	B13 Max. Humidity 75%	C13 Min. temp 18°C	D13 Timer 2 OFF Time 20.00	X13 Temp unit °C F
	A22 ON time 15 sec	B14 Temp. Fault Adj 0 +/- °C	C14 %rh fault Adj. 0 +/- %	D14 Timer 3 ON/OFF OFF, ON	
	A23 OFF time 60 min		C21 Various %rh OFF, ON	D15 Timer 3 ON Time 08.00	
	A24 Drain - auto OFF, ON		C22 Var. Min. temp. 20°C	D16 Timer 3 OFF Time 20.00	
	A25 ON time 30 sec		C23 Var. Max. Temp. 25°C		X21 Tandem ON/OFF OFF, ON
	A26 OFF time 6 hour		C24 Var. Change %rh 10%		X22 Max. ON time 120 sec

LEVEL 1 - User

A	ON/OFF Reg.	B	Temp. reg.	C	Humidity reg.
25°C	65%	25°C	65%	25°C	65%
A01	ON Time	B01	Min. temp.	C01	Min. Humidity
10 sec		20°C		60%	
A02	OFF Time	B02	Max. Temp.	C02	Max. Humidity
10 sec		30 °C		75%	
A03	Wetting	B03	Fixed On Time	C03	Fixed On Time
OFF, ON		10 sec		10 sec	