

<b>LEVEL 1 - User</b>	A	ON/OFF Reg. 25°C      65%	B	Temp. reg. 25°C      65%	C	Humidity reg. 25°C      65%	D	Timer	X	Service
	A01	ON Time 10 sec	B01	Min. temp. 20°C	C01	Min. Humidity 60%	D01	Timer 1 ON/OFF OFF, ON	X01	Level select 1    2, 3
	A02	OFF Time 10 sec	B02	Max. Temp. 30 °C	C02	Max. Humidity 75%	D02	Timer 1 ON Time 08.00	X02	Show Date/Time Date                      Time
	A03	Wetting OFF, ON	B03	Fixed On Time 10 sec	C03	Fixed On Time 10 sec	D03	Timer 1 OFF Time 20.00	X03	SW version Just info
<b>LEVEL 2</b>	A11	Dust - manuel 60 sec	B11	OFF various 120 sec      max	C11	OFF various 120 sec      max	D11	Timer 2 ON/OFF OFF, ON	X11	ON Time
	A12	Disinfection OFF, ON	B12	Off Time Min 0	C12	Off Time Min 0	D12	Timer 2 ON Time 08.00	X12	Reset To Default No    Yes
	A13	Smartphone OFF, ON	B13	Max. Humidity 75%	C13	Min. temp 18°C	D13	Timer 2 OFF Time 20.00	X13	Temp unit °C    F
<b>LEVEL 3</b>	A21	Dust - Auto OFF, ON	B14	Temp. Fault Adj 0 +/-°C	C14	%rh fault Adj. 0 +/- %	D14	Timer 3 ON/OFF OFF, ON		
	A22	ON time 15 sec			C21	Various %rh OFF, ON	D15	Timer 3 ON Time 08.00		
	A23	OFF time 60 min			C22	Var. Min. temp. 20°C	D16	Timer 3 OFF Time 20.00		
	A24	Drain - auto OFF, ON			C23	Var. Max. Temp. 25°C			X21	Tandem ON/OFF OFF, ON
	A25	ON time 30 sec			C24	Var. Change %rh 10%			X22	Max. ON time 120 sec
	A26	OFF time 6 hour								
	A27	Bleed off - Auto OFF, ON								

**LEVEL 1 - User**

A	ON/OFF Reg.
25°C	65%

B	Temp. reg.
25°C	65%

C	Humidity reg.
25°C	65%

A01	ON Time
10 sec	

B01	Min. temp.
20°C	

C01	Min. Humidity
60%	

A02	OFF Time
10 sec	

B02	Max. Temp.
30 °C	

C02	Max. Humidity
75%	

A03	Wetting
OFF, ON	

B03	Fixed On Time
10 sec	

C03	Fixed On Time
10 sec	