

LEVEL 1 - User	A	ON/OFF Reg.	25°C	65%	B	Temp. reg.	25°C	65%	C	Humidity reg.	25°C	65%	D	Timer	X	Service
	A01	ON Time	10 sec	B01	Min. temp.	20°C	C01	Min. Humidity	60%	D01	Timer 1 ON/OFF	OFF, ON	X01	Level select	1	2, 3
	A02	OFF Time	10 sec	B02	Max. Temp.	30 °C	C02	Max. Humidity	75%	D02	Timer 1 ON Time	08.00	X02	Show Date/Time	Date	Time
	A03	Wetting	OFF, ON	B03	Fixed On Time	10 sec	C03	Fixed On Time	10 sec	D03	Timer 1 OFF Time	20.00	X03	SW version	Just info	
LEVEL 2	A11	Dust - manuel	60 sec	B11	OFF various	120 sec	max	C11	OFF various	120 sec	max	D11	Timer 2 ON/OFF	OFF, ON	X11	ON Time
	A12	Disinfection	OFF, ON	B12	Off Time Min	0	C12	Off Time Min	0	D12	Timer 2 ON Time	08.00	X12	Reset To Default	No	Yes
	A13	Smartphone	OFF, ON	B13	Max. Humidity	75%	C13	Min. temp	18°C	D13	Timer 2 OFF Time	20.00	X13	Temp unit	°C	F
LEVEL 3	A21	Dust - Auto	OFF, ON	B14	Temp. Fault Adj	0 +/-°C	C14	%rh fault Adj.	0 +/- %	D14	Timer 3 ON/OFF	OFF, ON				
	A22	ON time	15 sec					C21	Various %rh	OFF, ON	D15	Timer 3 ON Time	08.00			
	A23	OFF time	60 min					C22	Var. Min. temp.	20°C	D16	Timer 3 OFF Time	20.00			
	A24	Drain - auto	OFF, ON					C23	Var. Max. Temp.	25°C					X21	Tandem ON/OFF
	A25	ON time	30 sec					C24	Var. Change %rh	10%					X22	Max. ON time
	A26	OFF time	6 hour													120 sec
	A27	Bleed off - Auto	OFF, ON													

LEVEL 1 - User

A	ON/OFF Reg.
25°C	65%

B	Temp. reg.
25°C	65%

C	Humidity reg.
25°C	65%

A01	ON Time
10 sec	

B01	Min. temp.
20°C	

C01	Min. Humidity
60%	

A02	OFF Time
10 sec	

B02	Max. Temp.
30 °C	

C02	Max. Humidity
75%	

A03	Wetting
OFF, ON	

B03	Fixed On Time
10 sec	

C03	Fixed On Time
10 sec	